

Southern California Edison
2026-WMPs – 2026-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 5 - S C E - 0 1 4

To: OEIS
Prepared by: Raymond Fugere
Job Title: Director
Received Date: 7/25/2025

Response Date: 7/30/2025

Question 01.a-b:

Regarding Traveling Faults:

With regard to SCE's response to DR #10, SCE states that it "is evaluating risk from traveling faults (i.e., faults that occur in a particular location, but travel along connected wires and release fault energy upstream or downstream)."

- a. Explain the scope and intended outcome of this evaluation.
- b. Provide the results of this evaluation including any reports with its current findings, and/or evaluation of the risk caused by traveling faults.

Response to Question 01.a-b:

- a) The scope of the evaluation is a review of CPUC-reportable and non-reportable ignitions that occurred between 2019 and 2024. The intended outcome is to better understand the risks associated with traveling faults and to develop recommendations to address the identified risks.
- b) The referenced evaluation is ongoing, and there is no report or finalized findings from the evaluation at this time.