

Southern California Edison
2026-WMPs – 2026-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 5 - S C E - 0 1 1

To: OEIS
Prepared by: Napa Tayavibul
Job Title: Senior Advisor
Received Date: 7/18/2025

Response Date: 8/6/2025

Question 001 Supplemental:

Regarding Public Resource Code Section 4292 Non-Exempt and Exempt Pole Clearing:

- a. Complete the table below regarding SCE's pole clearing work in State Responsibility Areas (SRAs) located within the HFTD from 2022 to 2024:

SRA within the HFTD PRC 4292 Exempt/Non-Exempt Pole Statistics

	2022	2023	2024
Total Number of Poles with PRC 4292 Exempt and Non-Exempt Equipment			
Number of Poles with PRC 4292 Exempt Equipment			
Number of Cleared Poles with PRC 4292 Exempt Equipment			
Number of Poles with PRC 4292 Non-Exempt Equipment			
Number of Cleared Poles with PRC 4292 Non-Exempt Equipment			

- b. Complete the table below regarding SCE's pole clearing work in Local Responsibility Areas (LRAs) located within the HFTD from 2022 to 2024:

LRA within the HFTD PRC 4292 Exempt/Non-Exempt Pole Statistics

	2022	2023	2024
Total Number of Poles with PRC 4292 Exempt and Non-Exempt Equipment			
Number of Poles with PRC 4292 Exempt Equipment			
Number of Cleared Poles with PRC 4292 Exempt Equipment			
Number of Poles with PRC 4292 Non-Exempt Equipment			
Number of Cleared Poles with PRC 4292 Non-Exempt Equipment			

- c. Complete the table below regarding SCE's pole clearing work in Federal Responsibility Areas (FRAs) located within the HFTD from 2022 to 2024:

FRA within the HFTD PRC 4292 Exempt/Non-Exempt Pole Statistics

	2022	2023	2024
Total Number of Poles with PRC 4292 Exempt and Non-Exempt Equipment			
Number of Poles with PRC 4292 Exempt Equipment			
Number of Cleared Poles with PRC 4292 Exempt Equipment			
Number of Poles with PRC 4292 Non-Exempt Equipment			
Number of Cleared Poles with PRC 4292 Non-Exempt Equipment			

Response to Question 001 Supplemental:

On July 15, 2025, SCE submitted a response to a data request from OEIS regarding historical structure brushing information, data request titled, OEIS-P-WMP_2023-SCE-011, Question 001.

During a conversation with OEIS on July 24, 2025, SCE indicated that it included poles without equipment in the PRC 4292 categories. OEIS requested the number of poles with no equipment that were included in those categories. Pursuant to that request, SCE is submitting a supplemental response to its original data request to provide a snapshot as of July 2025 the number of structures without equipment. Providing this for previous years would be an extensive manual effort involving numerous assumptions, given that SCE's system has changed over time (e.g. new equipment installed), changing FRA/LRA/SRA borders, and improved identification of exempt/non-exempt equipment. To clarify the prior response, SCE provided numbers that only included structures that were within the scope of SCE's structure brushing program. The table below includes all structures in SCE's HFRA.

For purposes of the table below, SCE is treating primary structures with no equipment as structures without transformers, capacitors, switches, reclosers, lightning arresters, and fuses, as well as secondary structures without reclosers.

	FRA (Federal Responsibility Areas)	LRA (Local Responsibility Areas)	SRA (State Responsibility Areas)	Total
Number of Structures with Exempt Equipment	876	18,073	15,963	34,912
Number of Structures with Non-Exempt Equipment	10,974	47,286	71,670	129,930
Number of Structures Without Equipment	16,203	41,742	85,343	143,288
Total Number of Structures with Exempt and Non-Exempt Equipment and no Equipment	28,053	107,101	172,976	308,130