



August 12, 2025

**DATA REQUEST RESPONSE
LS POWER GRID CALIFORNIA (LSPGC)**

Data Request No: OEIS-P-WMP_2025-LSP-002

Request Party: Office of Energy Infrastructure Safety

Originator: Johan Im, Wildfire Safety Analyst

Johan.Im@energysafety.ca.gov

cc:

Nicole Dunlap

Nicole.Dunlap@energysafety.ca.gov

Dakota Smith

Dakota.Smith@energysafety.ca.gov

Robert Warwick

Robert.Warwick@energysafety.ca.gov

Alex Weissman

Alex.Weissman@energysafety.ca.gov

Colin Lang

Colin.Lang@energysafety.ca.gov

Date Received: Thursday, August 07, 2025

Due Date: Wednesday, August 12, 2025

Please find enclosed LSPGC's response to OEIS data request Q01 – Q02. The following information is provided by the following individual:

Q#	Information Provided By	Affiliation to LSPGC	Contact	Business Address

01 – 02	Rituraj Yadav, Associate Manager, Wildfire Mitigation	Employee	208-281-8255 / ryadav@lspower.com	1122 S. Capital of Texas Hwy, STE 100, Austin, TX 78746
------------	--	----------	--------------------------------------	---

If you have any questions, please contact me at ryadav@lspower.com or 208-281-8255.

Sincerely,
Rituraj Yadav

OEIS Data Request Q01

Regarding Vegetation Management Procedures Documents:

- a) Provide the most recent versions of the following procedures documents referenced in the 2026–2028 Base WMP:
 - i. Transmission Vegetation Management Program Policy and Procedures
 - ii. LSPGC Substation Defensible Space Procedure
 - iii. LSPGC Emergency Operations Plan.
- b) Sections 9.2, 9.2.1.3, 9.2.2.3, 9.2.3.3, 9.3.2, 9.4.2, and 9.10.2 in the 2026–2028 Base WMP refer to NERC FAC-003-4. Did LS Power intend to reference the most current version of the reliability standard, NERC FAC-003-5?

Response to OEIS Data Request Q01

- a) Please refer to the attachments.
 - a. TVMP Policy and Procedures filed via e-file system. Name of the documents are listed below:
 - i. "LSPGC TVMP Policy v1.1"
 - ii. "LSPGC TVMP Procedure v1"

- b. LSPGC Substation Defensible Space Procedure file via e-file system. The name of the document is listed below:
 - i. "LSPGC Substation Defensible Space v1.1"
 - c. LSPGC Emergency Operations Plan file via confidentiality e-file system. The name of the document is listed below:
 - i. "LSPGC EOP-11 Emergency Operations Plan v.1"
- b) Yes, we intended to refer to NERC FAC-003-5. This has been fixed via substantive errata e-filed by LSPGC on 08/08/2025.

OEIS Data Request Q02

Regarding Section 9.12.1 Work Orders Priority Assignment:

Pursuant to GO 95 Rule 18(B)(1)(a)(i), a level 1 priority condition requires the electrical corporation "Take corrective action immediately, either by fully repairing the condition, or by temporarily repairing and reclassifying to a lower priority." LSPGC Table 9-1 in the 2026-2028 Base WMP defines Priority 1 "Risk Level" as "Immediate safety, reliability, or fire risk with potential for significant impact," and "Response" as "Address as soon as possible."

- a) Define "as soon as possible" as used above. Include the maximum time in hours allowed between identifying a Priority 1 issue and fully repairing, or temporarily repairing and reclassifying, the issue.
- b) Define "Immediate safety, reliability, or fire risk" as used above.

Response to OEIS Data Request Q02

- a) LSPGC defines "as soon as possible" for Priority 1 conditions as:
 - Corrective action must be taken immediately, or within 96 hours, with a reporting allowance of up to 30 days.

LSPGC currently has no energized transmission lines; its first line is expected to enter service in Q2 2028. LSPGC will develop supporting documentation consistent with 2026-2028 WMP initiatives.

b) “Immediate safety, reliability, or fire risk,” as referenced in LSPGC Table 9-1 under Priority 1 “Risk Level,” refers to any observed condition or hazard that:

- Poses a direct threat to public or worker safety (e.g., downed conductors, exposed energized components, equipment failure in proximity to public areas)
- Compromises the operational reliability of the electrical system (e.g., critical infrastructure outage, imminent risk of cascading failure)
- Presents a significant potential for fire ignition or propagation, particularly in high fire-threat districts (e.g., vegetation contacts with conductors, failed fire protection devices, or compromised fire hardening infrastructure).

LSPGC currently has no energized transmission lines; its first line is expected to enter service in Q2 2028. LSPGC will develop supporting documentation consistent with 2026–2028 WMP initiatives .