

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigations Plans Discovery 2026-2028**  
**Data Response**

<b>PG&amp;E Data Request No.:</b>	OEIS_019-Q002
<b>PG&amp;E File Name:</b>	WMP-Discovery2026-2028_DR_OEIS_019-Q002
<b>Request Date:</b>	August 19, 2025
<b>Requester DR No.:</b>	OEIS-P-WMP_2025-PG&E-019
<b>Requesting Party:</b>	Office of Energy Infrastructure Safety
<b>Requester:</b>	Nathan Poon
<b>Date Sent:</b>	August 27, 2025

**QUESTION 002**

**Regarding 2024 aerial inspection findings**

In response to OEIS\_005-Q001, PG&E stated that it performed 216,796 aerial inspections in 2024.

- a. Provide the number of level 1 work orders and the number of level 2 work orders in the HFRA/HFTD that resulted from distribution aerial inspections in 2024.

**ANSWER 002**

Table 1: Number of Work Orders from 2024 Distribution Aerial Inspections<sup>6</sup> in HFTD-HFRA

Work Order Level	Work Orders from 2024 Distribution Aerial Inspection in HFTD-HFRA <sup>3</sup>
Level 1 <sup>1</sup>	491 <sup>4</sup>
Level 2 <sup>2</sup>	52,658 <sup>5</sup>

Notes:

1. Level 1 work orders are A priority notifications including notifications identified in the field.
2. Level 2 work orders are X, B, E, or H priority notifications.
3. Excludes work orders created to document an inspection access issue ("CGI" notifications). These work orders do not document maintenance activity.
4. Includes work order categories reported in QDR responses (major work categories 17, BH, 95, IF)
5. Includes work order categories reported in QDR responses (major work categories 07, 2A, KA, GA).

6. Aerial Inspections are understood to be inspections planned and executed in HFTD-HFRA to meet commitments described in WMP 2023-2025 Section 8.1.3.2.7 in 2024.