

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigations Plans Discovery 2026-2028
Data Response

PG&E Data Request No.:	OEIS_021-Q001
PG&E File Name:	WMP-Discovery2026-2028_DR_OEIS_021-Q001
Request Date:	September 2, 2025
Requester DR No.:	OEIS-P-WMP_2025-PG&E-021
Requesting Party:	Office of Energy Infrastructure Safety
Requester:	Nathan Poon
Date Sent:	September 8, 2025

QUESTION 001

Regarding Transmission Work Orders

- a. Provide the number of level 1 and 2 work orders created on PG&E's transmission system in 2020, 2021, 2022, 2023 and 2024.
- b. Provide the number of level 1 and 2 work orders closed on PG&E's transmission system in 2020, 2021, 2022, 2023, and 2024.
- c. Provide the number of transmission work orders that had due dates extended later than Dec 31, 2024, when PG&E aligned its internal required end dates of A, E, and F tags with the maximum allowable Rule 18 remediation timeframes for Level 1, 2 and 3 conditions in early 2023.

ANSWER 001

- a. Level 1 and Level 2 findings are provided for 2020-2024 below, using the supporting dataset for 2025 Q2 QDR Table 2, Question 14.

	2020	2021	2022	2023	2024
Level 1 findings	904	857	547	1,053	783
Level 2 findings	29,425	37,109	34,393	28,788	23,234

- b. Level 1 and Level 2 closures are provided for 2020-2024 below, using the supporting dataset for 2025 Q2 QDR Table 2, Question 15.

	2020	2021	2022	2023	2024
Level 1 findings fixed	909	819	589	1,038	798
Level 2 findings fixed	25,839	25,062	25,379	27,369	26,596

- c. 40,159 LC notifications were updated during PG&E's internal required end date realignment from A/B/E/F to Level 1, 2, 3 and currently have a due date after December 31, 2024.