

December 1, 2025

BY ENERGY SAFETY E-FILING

Patrick Doherty
Program Manager | Compliance Assurance Division
Office of Energy Infrastructure Safety
715 P Street 20th Floor
Sacramento, CA 95814

Subject: Bear Valley Electric Service, Inc. Response to Notice of Non-Performance-NON_CAD_BVES_KSF_20250820_1100 (No Written Hearing Requested)

Dear Patrick Doherty:

Bear Valley Electric Service, Inc. (BVES) is providing a response to the Notice of Violation NON_CAD_BVES_KSF_20250820_1100. The enclosed response describes corrective actions taken to by BVES to remedy the findings identified in the above notice.

If you have any questions, or require additional information, please contact Jared Hennen at 909-255-2948 or <u>Jared.Hennen@bvesinc.com</u>.

Sincerely,

/s/ Jared Hennen
Jared Hennen
Wildfire Mitigation and Reliability Engineer
Bear Valley Electric Service, Inc.

BVES RESPONSE

Notice of Violation: NON_CAD_BVES_KSF_20250820_1100

Finding: On Pole ID 13045BV, Grid Hardening ID FW_50, at Mile 51.1 State Rte 18 S, Big Bear Lake, CA, 92315, USA, 34.2498027777272, -116.88383055559, the inspector observed that while a new wooden pole was installed, it was not fire wrapped. The inspector's observation is documented in Deficiency 1 photographs, which are attached to this report. Photo numbers Glmg1, Glmg2, IA1Img1 and IA1Img2 depict incomplete installation of fire-resistant pole wrap.

Response: BVES was made aware of the violation on November 10, 2025. Crews were dispatched to the location of pole number 13045BV located at (Lat/Long: 34.2498027777272, -116.88383055559) on November 18, 2025. Crews wrapped the pole with fire wrap to BVES specs. See pictures below for completed work.



