

November 24, 2025

VIA ELECTRONIC FILING

Docket # 2025 NON

Sheryl Bilbrey
Program Manager
Environmental Science Division
Office of Energy Infrastructure Safety
715 P Street, 20th Floor
Sacramento, CA 95814
Sheryl.birlbrey@energysafety.ca.gov

**RE: PacifiCorp's Response to Notice of Non-Performance –
NON_ESD_PC_MAZ_20250910_0906**

Dear Sheryl Bilbrey:

PacifiCorp provides the following response to the finding identified in the Notice of Non-Performance," *NON_ESD_PC_MAZ_20250910_0906* (NON) issued by the Office of Energy Infrastructure Safety (Energy Safety) on October 27, 2025. On September 10, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Hornbrook, California.

Energy Safety found the following deficiency:

Deficiency 1. Energy Safety observed that in implementing 2025 WMP initiative 8.2.3.2 Clearance, PacifiCorp failed to adhere to its protocol of achieving vegetation clearance for distribution lines along the conductor near Pole ID 06247006-211003, Vegetation Management ID DN_Insp_2025_5G19 at coordinates 41.906507, -122.547518. Energy Safety considers this non-performance to be in the Moderate risk category. PacifiCorp must complete corrective action for this non-performance by six months from date of the notice.

PacifiCorp Response:

In response to the NON, the company conducted a field inspection and pruned the tree on November 1, 2025, to meet clearance compliance. On November 8, 2025, the company verified that the tree had been removed. The removal was performed as a corrective action in accordance with the NON. Please see image below for reference.



**Tree Removal Near Pole ID 06247006-211003, at Coordinates 41.906507, -122.547518.
Picture taken November 8, 2025.**

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NON_ESD_PC_MAZ_20250910_0906.

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at pooja.kishore@pacificorp.com and californiadockets@pacificorp.com.

Sincerely,

Carrie Laird

Carrie Laird

Vice President, Wildfire Mitigation and Emergency Operations

cc: environmentalscience@energysafety.ca.gov
Max.Zazzeron@energysafety.ca.gov
Elizabeth.McAlpine@energysafety.ca.gov